

SWEDISH TECHNICAL APPROVAL 0974/75

and decision on production control in accordance with 18-20 § Law (1994:847) on technical specification requirements for construction work, etc., BVL

KEY WORD: SURFACE WATER
Roof drainage systems

LINDAB RAINLINE

Holder	Lindab Profil AB, SE-269 82 BÅSTAD, phone: +46 431-850 00, fax: +46 431-851 50, profil@lindab.se, www.lindab.se, vat nr: 556071-4320
Product	Roof drainage system of hotdip galvanized steel sheet Z275, lacquered-hotdip galvanized or aluzinc-covered steel sheet AZ150 and copper sheet. Gutters and pipes are manufactured in thickness of material of 0.6 and 0.7mm. When it is indicated roof drainage system meet the requirements according to SS-EN 612:2005 or SS-EN 1462:2004.
Intended use	Collection and draining of rainwater from roof.
Trade name	Lindab Takavvattning och Lindab Rainline
Approval	The products satisfy the requirements set forth in 2 § 3 BVL, in respect to and under conditions stated in this certificate, and are therefore approved in accordance with the provisions of the following sections of the Building Regulations issued by the National Board of Housing, Building and Planning (<i>BBR</i>). Surface water, generally 6:622, 1st section Material m.m. 6:624, 1st sentence
Appurtenant Documents	Lindab Profils product catalogue section Rainline. Lindab Rainline "Takavvattning-det kompletta systemet", p.8-10, dated 4.4.2005.
Control	Production control is to be performed in accordance with instructions for control dated 26.6.2006. An independent third-party body, SP Swedish National Testing and Research Institute, audits the control. When the building proprietor performs inspection at the building site, he shall check the markings to ensure that the correct products have been supplied and that they are used in accordance with requirements stated in the approval and the appurtenant documents. He must also check that the product is accompanied by a manufacturing assurance, which certifies that the product has been manufactured in accordance with the documents on which this certificate is based.

4.7.2006

Certificate No. 0974/75

Manufacturer	Production control includes the following site: Lindab Profil AB, Båstad
Marking	The product shall be marked on the packaging at the factory and contain the following information: Approval holder/Manufacture site Boverket's registered trademark SITAC's accreditation number Product type designation Approval certificate number Date of manufacture Material Inspection body
Basis for approval	Report BTKP005074A and P400319A from Swedish National Testing and Research Institute (SP).
Comments	This approval supersedes previous certificate with the same number dated 16.10.2000 and Reg. No. T000931.
Period of validity	This approval is valid until 3.7.2011. The formal validity of an approval expires after the transitional period for the harmonised specification that makes it possible to CE-mark the product. However, the technical assessment showing that the product fulfils the requirements in the building regulations, issued by the Swedish National Board of Housing, Building and Planning, is not affected.

LINDAB, Båstad**SITAC 1422****designation****0974/75****date****Metallized steel or copper****SP**

Johan Åkesson

Agneta Karlsson