

Nr 189-02/05

SERTIFIKAAT

CERTIFICATE



Product

Insulation boards "ISOPLAAT"

Manufacturer/Supplier

AS Viisnurk (Reg code: 10106774)
Address: Rääma 31, Pärnu 80044, ESTONIA

Product description

Structure: wood fibres, paraffins emulsion

Thickness: 13 mm (25 mm), density is approximately 250kg/m³

Field of use: Insulation boards for external wall.

Classification standard

EVS-EN 13501-1:2004 "Fire classification of construction products and building elements. Part 1: Classification using test data from reaction to fire tests".

Classification

Based on test results (EVS-EN 13501-1:2004) "ISOPLAAT" meets the reaction to fire class:
B-s2-d0, installed to the non-compostubile underlay (thermal insulation) with reaction to the fire classification A1 or A2.

Basis

1. Assessment report No AK-18-05;
2. Decision of the board No 65/09/05, 16.09.2005.

Quality control

Quality control is carried out according to contract No 40-3005(10)/99-0032 (VTT).

Certificate validity conditions

Present certificate is valid from 16.09.2005 till 16.09.2008 on condition that regular quality inspection is performed in due time.

KOOPIA

Janek Neltsas

Chief executive



PC 015 (EN 45011)
1 032 (EN 45004)

Sertifitseerimisbüroo EstCert OÜ
Reg nr 10952693
Täht 1-ku, 10621 Tallinn

Tel: +372 651 7797
Fax: +372 651 7796
e-mail: info@estcert.ee